



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE160305004992-A1/H1

Product Thermal overload relay

Applicant Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model TGR1-38,TGRH-38

Technical data Uimp:6kV;Ui:690V; Ue:690V;Ie: 9~13A,12~18A,17~
25A,23~32A,30~38A;Tripping
class:10A;3P;IP20;Auxiliary
contacts:1NO,1NC;Ith:5A;AC-15:
Ue/Ie220V/1.64A,380V/0.95A;DC-13: Ue/Ie220V/0.15A

This is to certify that, on the basis of the tests undertaken as per Report No.
0901-CE2016CQC0305-007761-A1/H1, the submitted sample(s) of the above item
complies with:

EN 60947-4-1:2010 + A1:2012

and fulfills testing requirements of the European Directive:
2014/35/EU

Valid from: May.16,2019

Valid until: May.16,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>