



Ref. Certif. No.

HU-003802

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|---|---|
| Product | Circuit Breaker for Overcurrent Protection |
| Name and address of the applicant | Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China |
| Name and address of the manufacturer | Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China |
| Name and address of the factory | Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China |
| Ratings and principal characteristics | Ue: AC 220V/230V/240V; In: 6A, 10A, 16A, 20A, 25A, 32A, 40A; Instantaneous Tripping Current: Type C, Type D; Ics=Icn: 4500A; Number of Poles: 1P+N (One N pole acting together with a protective pole); Ui: 690V; Uimp: 4.0kV |
| Trademark (if any) | Tengen (Logo) |
| Customer's Testing Facility (CTF) Stage used | N/A |
| Model / Type Ref. | TGB1N-40 , TGB1N-40A |
| Additional information (if necessary may also be reported on page 2) | Detailed information refer to test report CN22QD1J 001. |
| A sample of the product was tested and found to be in conformity with | IEC 60898-1:2015+A1 |
| As shown in the Test Report Ref. No. which forms part of this Certificate | CN22QD1J 001 |

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2022-03-08

Signature:

Wencai Zhang